



1. Substrate designed to 1:40 falls (or flat with Tapered Insulation) primed with appropriate SIGNature Primer.
2. Spectravap Polyethylene Vapour Control Layer.
3. SIGNature approved PIR Insulation, Tapered/Flatboard - thickness to achieve design U-value, designed to 1:40 falls as per BS6229:2018).
4. IKOfix Insulation Tube with appropriate IKOfix Fixing - see IKO Fixing Guide for Tube and Fixing length.
5. Armourplan P / SM membrane.
6. Min. 60mm Hot Air Weld.
7. Armourplan Cover Strip.
8. Armourplan Peel Stop bar fixed with appropriate IKOfix fixings - Peel stop termination to be installed horizontally or vertically.
9. Armourplan PVC Conatact Adhesive
10. SIGNature approved PIR Upstand Insulation - mech fixed.
11. Armourplan membrane coated bespoke chased metal, mech fixed with appropriate IKOfix Fixing.
12. Spectravap Joniting Tape.
13. Armourplan PVC Sealant.

The Waterproofing System should be installed in accordance with BS6229:2018 and Accuroof project Specification.

The details shown are indicative and for approval only and do not form part of any contract.

Data sheets for all IKO Polymeric and IKO PLC products are available on request.

Project specifications are available on request.

A	11/10/23	BP	Original Detail
Rev:	Date:	By:	Description:



Unit 31F, Mannheim House, Gelders Hall Road,  
Shepshed, Loughborough, LE12 9NH  
Tel: 01509 501731  
Email: Technical@accuroof.co.uk  
Web: www.accuroof.co.uk

Drawing No:	SIG-ASM-03	Rev:	A
-------------	------------	------	---

Scale:	Not To Scale	Date:	11/10/2023
--------	--------------	-------	------------

Drawing:  
Abutment to Brickwork - Chased Joint Insulated