



1. Substrate to minimum of 1:80 achieved falls, to be smooth clean, dry and free from dust, grease and frost, primed with SIGNature Ultra Protect AVCL / Carrier Primer.
2. SIGNature Ultra Protect approved Self Adhesive Carrier Membrane / Air & Vapour Control Layer (AVCL) overlapped at edges by 50-80mm and 150mm minimum at roll ends.
3. AccuRoof Supplied Insulation bonded with IKOpro High Performance PU Adhesive, primed with SIGNature Ultra Protect AVCL / Carrier Primer.
4. SIGNature Ultra Protect Base Coat (1no application of 1 l/m² coverage).
5. SIGNature Ultra Protect Chop Strand Mat Reinforcement minimum overlap of 50mm.
6. SIGNature Ultra Protect Top Coat (1no application of 1 l/m² coverage for 20 year system or 2no applications of 0.75 l/m² coverage for 25 year system, Each application of liquid needs to cure prior to applying the next).
7. Paving Slabs on Proprietary Supports on AccuRoof Protection Layer.
8. 50mm overlap of Uprand Liquid & Reinforcement to Field Area Liquid & Reinforcement.
9. AccuRoof Supplied Insulation mech fixed and primed with SIGNature Ultra Protect AVCL / Carrier Primer.
10. Galvanised Metal Hard Edge to be cleaned and primed with SIGNature Ultra Protect Fast-Cure Multipurpose Primer.
11. AccuRoof Supplied fixings.
12. 0.5 l/m² of SIGNature Ultra Protect Top Coat with sharp sand broadcast into whilst wet to give mortar a "key"
13. Cementitious and Flexible Frost Proof Mortar.
14. Proprietary Coping Stone.
15. Galv Metal cavity closer by others - mech fixed

The waterproofing system should be installed in accordance with BS6229 (current), LRWA Guidelines and relevant Codes of Practice.

Project specifications are available on request.

Data sheets for all AccuRoof supplied products are available on request.

The details shown are indicative and for approval only and do not form part of any contract.

Further information on all AccuRoof products and services can be obtained through the contact details printed below.

A	28/04/22	PS	Original Detail
Rev:	Date:	By:	Description:



Unit 31F, Mannheim House, Gelders Hall Road,
 Shepshed, Loughborough, LE12 9NH
 Tel: 01509 501731
 Email: Technical@accuroof.co.uk
 Web: www.accuroof.co.uk

Drawing No:	SIGUP-12	Rev:	A
-------------	----------	------	---

Scale:	Not To Scale	Date:	28/04/2022
--------	--------------	-------	------------

Drawing: SIGNature Ultra Protect Parapet Detail with Walkway